



Pace Analytical Services, Inc.  
1800 Elm St SE Suite #1830  
Minneapolis, MN 55414  
Phone: 612.656.1144  
Fax: 612.656.1181  
www.pacelabs.com

**LABORATORY ANALYSIS REPORT**

**DATE:** 2015-01-22  
**CLIENT:** Vitev LLC  
2115 Lousiana St  
Lawrence,KS 66046

**PAGE:** 1 of 3  
**PROJECT:** 3047  
**COLLECTED BY:** CN  
**PROJECT REC'D:** 2015-01-15  
**PROJECT DESC:** Filter Materials

**CONTACT:** Gabe Hunninghake

Sample (s) analyzed according to CA Prop 65 Raw Material Sampling and Monitoring Protocol Section 1.5 Beaker Test Method.

Pace Analyticals Product Testing Division received 1 Filter Materials (s) for the analysis presented in the following report.

All data reported is associated with quality control that met method, EPA, NSF/ANSI or internal laboratory specification. Any exceptions are noted in a footnote or narrative format.

Pace Analytical Services, Inc. appreciates the opportunity to provide you with this product testing service. We value your feedback, would you please take a few minutes to access our customer satisfaction survey at: <http://www.pacelabs.com/my-account/customer-survey.html> . If you have any questions or comments regarding this report, please feel free to contact us.

Sincerely,

A handwritten signature in cursive script that reads "Carin Nawratil".

Enclosure



Pace Analytical Services, Inc.  
 1800 Elm St SE Suite #1830  
 Minneapolis, MN 55414  
 Phone: 612.656.1144  
 Fax: 612.656.1181  
 www.pacelabs.com

LABORATORY ANALYSIS REPORT

PROJECT: 3047

PAGE: 2 of 3

**CA Prop 65 Protocol Section 1.5 Beaker Test Method**

<b>Sample: 041851</b>		<b>Description: Influent</b>			<b>Volume: 10 Unit Volume</b>		
<u>Compound</u>	<u>Results</u>	<u>Units</u>	<u>Reporting Limit</u>	<u>Method</u>	<u>Date Collected</u>	<u>Date Analyzed</u>	
Calcium (Ca)	<20.00	ug/L	20.00	EPA 200.8	2015-01-16	2015-01-20	
Conductivity (wc)	<1.00	uS/cm	1.00	EPA 120.1	2015-01-16	2015-01-16	
Magnesium (Mg)	<10.00	ug/L	10.00	EPA 200.8	2015-01-16	2015-01-20	
pH (wc)	8.47	(None)	NA	EPA 150.1	2015-01-16	2015-01-16	
Potassium	<10.00	ug/L	10.00	EPA 200.8	2015-01-16	2015-01-20	
Sodium	37.15	ug/L	10.00	EPA 200.8	2015-01-16	2015-01-20	
Temperature (wc)	14.5	°C	NA	EPA 150.1	2015-01-16	2015-01-16	

**CA Prop 65 Protocol Section 1.5 Beaker Test Method**

<b>Sample: 041852</b>		<b>Description: Filter Materials Good Minerals</b>			<b>Volume: 10 Unit Volume</b>		
<u>Compound</u>	<u>Results</u>	<u>Units</u>	<u>Reporting Limit</u>	<u>Method</u>	<u>Date Collected</u>	<u>Date Analyzed</u>	
Calcium (Ca)	8126.92	ug/L	1000.00	EPA 200.8	2015-01-16	2015-01-20	
Magnesium (Mg)	83985.50	ug/L	500.00	EPA 200.8	2015-01-16	2015-01-20	
Potassium	29435.65	ug/L	500.00	EPA 200.8	2015-01-16	2015-01-20	
Sodium	19126.54	ug/L	500.00	EPA 200.8	2015-01-16	2015-01-20	



Pace Analytical Services, Inc.  
1800 Elm St SE Suite #1830  
Minneapolis, MN 55414  
Phone: 612.656.1144  
Fax: 612.656.1181  
www.pacelabs.com

LABORATORY ANALYSIS REPORT

PROJECT: 3047

PAGE: 3 of 3

*This report has been reviewed for technical accuracy and completeness. The analyses were performed using EPA or other approved methodologies and the results were reported on an "as received" basis unless otherwise noted. These results relate only to the items tested.*

*NA = Not Applicable*

*su - Standard Units*

*UV - Unit Volume*

*mg/L = milligrams per Liter*

*ug/L = micrograms per Liter*

*GPM = Gallons Per Minute*

*NTU = Nephelometric Turbidity Unit*

*(wc) = Water Characteristics are for monitoring purposes only, quality control samples may or may not have been performed.*

**END OF DOCUMENT**